

1. PES Engineer is to field check site before temporary pole is set.
2. Pole is to be treated, and minimum 4" square or round.
3. Center of meter base to be between 5' and 6' above final grade.
4. Service entrance panel to be rated at least a 60 amp service.
5. Service pole must be inspected by the Tennessee State Deputy Wiring Inspector.
6. An anchor and guy must be installed if pole is further than 10' from PES pole, the anchor must have a "knuckle head" attachment for guy.

