



1. 2/0 BARE COPPER GROUNDING WIRE TO BE PLACED UNDER PAD BEFORE PAD IS POURED AND TO BE CONTINUOUS.
2. WIRE TO BE BONDED TO GROUND RODS WITH HEAVY BOLTED CLAMP.
3. LEAVE SLACK IN BARE CU GROUND WIRE IN HIGH AND LOW SIDE CAVITIES FOR P.E.S. TO ATTACH TO.
4. INSTALL CONDUIT GROUNDING BUSHING FOR EACH STEEL PRIMARY CONDUIT.
5. ALL MATERIAL ON THIS SHEET TO BE FURNISHED BY CUSTOMER UNLESS OTHERWISE SPECIFIED.

Note:
 This spec is to be used in conjunction with the general 3phs pad spec.

PULASKI ELECTRIC SYSTEM TYPICAL FOR CONCRETE PAD

| | | |
|---------------------|------------------|-----|
| Location: | | |
| Trans. 500 / 750kva | Gal. oil | LB. |
| Maker | Manufacture date | |
| S/N | | |
| Voltage 277/480 | Taps no | |
| %Z 1.5 | Fault Current | |