

Notes:

If the ditch does not reach the required depth. conduit is to be covered with 6" of concrete.

A 5/8" through bolt is required for stand-off bracket.

If the ditch crosses another utility, PES is to be loacted in the lower position and 6" of concrete separation is required. The concrete is to extend 18" either side of the crossing.

NO ditch can be covered until PES has performed an inspection and pulled a warning tape.

(O/D is to install tape 12" below final grade.)

Pulaski Electric System

Typical 1-Phase Primary Duct & Riser

revised March 2010